AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CO	NTRACT ID CODE J	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO.	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.			1 4 FNO.(If applicable)
0006	30-Dec-2004	W16ROE-4302-4908		J. PROSEC	(NOATI applicable)
6. ISSUED BY CODE	W912DS	7. ADMINISTERED BY (If other than item 6)		CODE	-64 13
USA ENGINEER DISTRICT, NEW YORK ATTN CENAN-CT ROOM 1843 26 FEDERAL PLAZA NEW YORK NY 10278		See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR	(No., Street, County, St	ate and Zip Code)	X 9A.AM	ENDMENT OF SO	LICITATION NO.
				TED (SEE ITEM 11	
			100,000	OD. OF CONTRAC	T/ORDER NO.
			10B. D/	TED (SEE ITEM	13)
CODE	FACILITY COL				
X The above numbered solicitation is amended as set forth		APPLIES TO AMENDMENTS OF SOLIC	TATIONS is extended	d. X js not ext	
Offer must acknowledge receipt of this amendment pric (a) By completing Items 8 and 15, and returning or (c) By separate letter or telegram which includes a re RECEIVED AT THE PLACE DESIGNATED FOR TH REJECTION OF YOUR OFFER. If by virtue of this a provided each telegram or letter makes reference to the	3 copies of the amendme ference to the solicitation and IE RECEIPT OF OFFERS PR mendment you desire to change	nt; (b) By acknowledging receipt of this amendment amendment numbers. FAILURE OF YOUR ACKN JOR TO THE HOUR AND DATE SPECIFIED MA is an offer already submitted, such change may be m	on each copy of I IOWLEDGMEN Y RESULT IN ade by telegram o	T TO BE	
12. ACCOUNTING AND APPROPRIATION DA	TA (If required)				
		TO MODIFICATIONS OF CONTRACTS/ CT/ORDER NO. AS DESCRIBED IN ITE			
A. THIS CHANGE ORDER IS ISSUED PURS CONTRACT ORDER NO. IN ITEM 10A.	SUANT TO: (Specify au	thority) THE CHANGES SET FORTH IN	ITEM 14 ARI	E MADE IN THE	
B. THE ABOVE NUMBERED CONTRACTA office, appropriation date, etc.) SET FORTE C. THIS SUPPLEMENTAL AGREEMENT IS	LIN ITEM 14, PURSUA	ANT TO THE AUTHORITY OF FAR 43.1		ich as changes in pa	ying
D. OTHER (Specify type of modification and a	uthority)	THE COLUMN AS SERVICES SAFETY OF THE COLUMN ASSETS			
E.)MPORTANT: Contractor is not,		gn this document and return	1/2	issuing office.	
14. DESCRIPTION OF AMENDMENT/MODIFI where feasible.) The solicitation is amended as follows: 1. To incorporate and reissue revised drawing. 2. To incorporate contractor(s') submitted of the bid opening date remains unchanged. NOTE: OFFERORS MUST ACKNOWLEDG AMENDED) BY ONE OF THE FOLLOWING TELEGRAM, OR BY SIGNING BLOCK 15 IN RESULT IN REJECTION OF YOUR BID IN BIDS (FAR14.304).1. CONTRACT ID COD	ngs: uestions and provide a SE RECEIPT OF THIS METHODS: IN THE BELOW. FAILURE TO ACCORDANCE WITH	AMENDMENT BY THE DATE SPECIF SPACE PROVIDED ON THE SF1442, ACKNOWLEDGE AMENDMENTS BY HITHE LATE BID, LATE MODIFICATIO	FIED IN THE BY SEPARA THE DATE ONS OF BIDS	SOLICITATION (6 TE LETTER, OR AND TIME SPEC FOR LATE WITH	BY IFIED MAY DRAWAL OF
Except as provided herein, all terms and conditions of the do	current referenced in Item 9A	or 10A, as heretofore changed, remains unchanged	and in fall force a	and effect.	
15A. NAME AND TITLE OF SIGNER (Type or	print)	16A. NAME AND TITLE OF CON		ONFFICER (Type or	printi)
15B-CONTRACTOR OFFERDR	ISC DATE SIGNE	D 16B. UNITED STATES OF AMER	EMAIL ICA]4:	6C. DATE SIGNED
	1	ВУ		1	30-Dec-2004
(Signature of person authorized to sign)		(Signature of Contracting Off	icer)		90-000-2004

EXCEPTION TO SF 36 APPROVED BY QIRM 11-84 30-105-04

STANDARD FORM 30 (Rev. 10-83) Prescribed by GSA FAR (48 CFR) 53 243 SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text: AMENDMENT 0006

The following changes shall be made to the drawings and specifications.

DRAWINGS

- The following DRAWINGS have been <u>REVISED</u> but not <u>REISSUED</u>: NONE
- The following DRAWINGS have been <u>REVISED</u> and <u>REISSUED</u>: NONE

SPECIFICATIONS

- 1. The following SPECIFICATION SECTIONS have been <u>ADDED</u> and are provided in their entirety herein: **NONE**
- 2. The following SPECIFICATIONS SECTIONS have been DELETED in their entirety: NONE
- 3. The following SPECIFICATIONS have been **REVISED** but **NOT REISSUED**:
- a. Section 04200, Masonry; In paragraph 3.2.4.4, Cavity Walls; **DELETE** the last sentence: [Cavity face of interior wythe shall be dampproofed in accordance with section 07112N BITUMINOUS DAMPPROOFING.].
- b. Section 05120, Structural Steel; **DELETE** the last sentence of paragraph 3.1; "Structural steelwork, except surfaces of steel to be encased in concrete, surfaces to be field welded, surfaces to be fireproofed, and contact surfaces of friction-type high-strength bolted connections shall be prepared for painting in accordance with endorsement "P" of AISC FCD and primed with the specified paint."
- c. Section 02556A, Gas Distribution Sysytem; In paragraph 1.1, References; Under the National Fire Protection Agency section ADD NFPA 54 National Fuel Gas Code.

BIDDER'S QUESTIONS AND GOVERNMENT REPLY

(Questions that may be of general interest of all bidders/Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or clarify and simplify the question(s). Questions and answers are issued to the Offerors/Bidders for information only.)

Question (Q): Detail B/A704 calls for a precast concrete Logo graphics. Is this a supplied graphic to be installed on the face of the precast or is it to be cast-in? If it is to be cast-in I need to know what they look like. Assume there are 2 on each side. Response (R): Detail B A704 is all brick with lettering attached, there is a precast concrete cap on top of the brick as shown on this detail.

Q: Specification 05120 paragraph 1.2 mentions to include shop primer. Paragraph 1.4 submittals SD-03 Product Data lists Shop primer and SD-06 Tests Reports lists Class B coating. Paragraph 3.1states surfaces to be prepared for painting in accordance with endorsement "P" of AISC FCD and primed with specified Paint. What is the specified paint and surface preparation? R: Specification 05120 calling for Class B coating is correct. Specification section 05120 has been revised as per this amendment; see above section for the revision that shall clarify this issue. It should be noted in specification 9900 paragraph 1.9.1.2 Interior Painting states to paint exposed columns, girders, beams joist and metal deck. However in paragraph 1.9.2 Painting Excluded states concealed surfaces need not be painted. I believe that none of the structural steel is exposed. Does the structural steel receive a primer? If yes what is the surface preparation and paint required. R: Priming of the steel is separate and apart from section 09900 interior painting. The Architectural section 09900 is correct; it pertains to painting not steel priming. These two issues are separate and apart; the fabricator does the priming, not interior painting. All steel (whether exposed or concealed) needs to be primed. See section 05120 paragraph 3.5.1 for information on dealing with field priming of steel.

Q: Referring to section 02556A, Gas distribution system, paragraph 2.3.2 and 2.4 The supplier of gas meters and regulators in Buffalo is unable to determine which type of equipment you are requesting and is unable to provide our firm with a price. R: Information on the gas meter and gas regulator requirements can be obtained from drawing M-509, Mechanical Details-7 on the Typical Gas Service (W/By-Pass) Detail and drawing M-600, Mechanical Schedules-1. M-509 has information regarding the external pressure coming into the building and M-600 has the Boiler schedule that can be used to determine the gas pressure required in the building. As per this amendment NFPA 54 was added to the reference section of specification 02556A to clarify requirements. In regards to paragraph 2.4, the 500 pulse per minute with no false pulses is a standard specification requirement.

Q: We propose to bid the fire sprinkler work to GC's. Would you please clarify requirements for seismic bracing and hangers for the sprinkler piping. Our interpretation of the specifications is that sprinkler piping larger than 2.5 inches needs to be braced. Several GC's have told me seismic bracing need only occur at the seismic joint of the building (Col. Line D), as shown on drawing S-107. R: The Bidders attention is directed to specification section 15070A for general guidance concerning the extent of seismic protection for all mechanical equipment and systems, paragraphs 1.2.3, 1.2.4, 1.2.5, 1.2.5.1 and 1.2.5.2. Seismic bracing is not limited to the seismic joint in the building.

- Q: In Amendment #0005, drawing A-503 was not revised as stated. R: The drawing was revised but not reissued in amendment #0005. The instructions for the revision to drawing A-503 are in the revised but not reissued section of the amendment.
- Q: Specification section 04200, Masonry, paragraph 3.2.4.4 indicated dampproofing the cavity face of the interior Wythe per Specification 07112H, Bituminous Dampproofing. This specification is not included in the bid documents. If this work is required, please provide this specification. R: This work is not required and the sentence in paragraph 3.2.4.4 that refers to specification section 07112H is to be removed as per this amendment.

The following question appeared in prior amendments, the bidders are advised to disregard in lieu of the following:

NONE

-- End of Section --

(End of Summary of Changes)